



## Legislation Details (With Text)

**File #:** 2006-0167      **Version:** 1

**Type:** Ordinance      **Status:** Passed

**File created:** 4/10/2006      **In control:** Capital Budget Committee

**On agenda:**      **Final action:** 4/24/2006

**Enactment date:** 5/3/2006      **Enactment #:** 15425

**Title:** AN ORDINANCE making a supplemental appropriation of \$3,960,000 of capital funds to provide the appropriate level of appropriation authority on an emergency basis for the Barton force main repair project in the conveyance pipelines appropriation project category; and amending the 2006 Budget Ordinance, Ordinance 15333, Section 116, as amended, and Attachment D, as amended.

**Sponsors:** Bob Ferguson

**Indexes:** Appropriation, Wastewater

**Code sections:**

**Attachments:** 1. 15425.pdf, 2. 2006-0167 Attachment 6 of 4-19-06 Staff Report.pdf, 3. 2006-0167 Emergency declaration.pdf, 4. 2006-0167 Fiscal Note.doc, 5. 2006-0167 Lincoln Park Barton FM Repair Ma2006-0167.pdf, 6. 2006-0167 Lincoln Park Emergency Waiver1.doc, 7. 2006-0167 Revised Staff Report 04-19-06.doc, 8. 2006-0167 Staff Report 4-19-06.doc, 9. 2006-0167 Transmittal Letter.doc, 10. A. Adopted Ordinance 15333, Section 116: Wastewater Treatment Capital Improvement Program, 11. A. Adopted Ordinance 15333, Section 116: Wastewater Treatment Capital Improvement Program

| Date      | Ver. | Action By                        | Action                  | Result |
|-----------|------|----------------------------------|-------------------------|--------|
| 4/24/2006 | 1    | Metropolitan King County Council | Hearing Held            |        |
| 4/24/2006 | 1    | Metropolitan King County Council | Passed                  | Pass   |
| 4/19/2006 | 1    | Capital Budget Committee         | Recommended Do Pass     | Pass   |
| 4/10/2006 | 1    | Metropolitan King County Council | Introduced and Referred |        |

Clerk 03/30/2006

AN ORDINANCE making a supplemental appropriation of \$3,960,000 of capital funds to provide the appropriate level of appropriation authority on an emergency basis for the Barton force main repair project in the conveyance pipelines appropriation project category; and amending the 2006 Budget Ordinance, Ordinance 15333, Section 116, as amended, and Attachment D, as amended.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

**SECTION 1. Findings.**

A. There is an emergency due to the failed section of the Beach Drive interceptor at Lincoln park in West Seattle that is leaking sewage onto Lincoln Park beach and into the Puget Sound.

B. On February 4, 2006, a section of the Beach Drive interceptor at Lincoln park in West Seattle failed causing sewage to leak onto the Lincoln park beach and into Puget Sound.

C. This was the second failure in less than one month, the first having occurred on January 17, 2006, and having been repaired on January 21, 2006.

D. Immediately after the February 4 failure, the wastewater treatment division ("WTD") of the department of natural resources and parks instituted tanker trucking operations to move sewage from the Barton pump station to the Murray pump station in order to reduce overflow sewage from entering Puget Sound. As the tanker trucking operations were only partially effective in that there was still an overflow of approximately one million gallons of sewage per day, six hundred feet out into Puget Sound, a temporary pump station was installed and a temporary line was laid along the beach to control sewage overflows.

E. Video inspection of the Beach interceptor after the February 4 failure revealed four other sections of the interceptor that are at imminent risk of failure. WTD has determined that further repair and use of the Beach Drive interceptor pipe at Lincoln park is not feasible and that the thirty-inch concrete cylinder force main should be replaced with two parallel twenty-four-inch diameter high density polyethylene pipes, one being inserted into the failed pipe and one being laid parallel to it.

F. The second failure of the Beach Drive interceptor and the imminent risk of failure of four additional sections of the interceptor and the resulting possibility of the release of overflow sewage onto Lincoln park beach and into Puget Sound, constitute an emergency situation that presents a real and immediate threat to public health, safety and welfare.

G. Pursuant to K.C.C. 4.16.050, on February 17, 2006, the King County executive issued a determination of emergency and waiver from procurement requirements to repair a failed section of the Beach Drive interceptor at Lincoln park in West Seattle that is leaking sewage onto Lincoln park beach and into the

Puget Sound, to protect public health, safety, welfare and property and the environment.

SECTION 2. Ordinance 15333 Section 116, as amended, is hereby amended by adding thereto and inserting therein the following:

The Barton Force Main Repair Project 423XXX, in appropriation project category A20500 Conveyance Pump Stations requires an appropriation of \$3,960,000 to cover all costs and expenses associated with the design, construction and completion of the emergency restoration.

| <u>Fund</u> | <u>Capital Fund</u>          | <u>Amount</u> |
|-------------|------------------------------|---------------|
| 4616        | Wastewater Treatment Capital | \$3,960,000   |

SECTION 3. Attachment A to this ordinance hereby amends Attachment D to

Ordinance 15333, as amended, by adding thereto and inserting therein the projects listed in Attachment A to this ordinance.

none